

SUBSTRUCTURE MASONRY STRENGTHS LEGEND

ALL SUBSTRUCTURE BLOCKWORK TO BE 7.3N/mm2, minimum class (ii) (M6) mortar
Beam & Block to Jet Floor Details

NOTE: Where infill blocks to beam and block floor are built into adjacent walls,
the infill block is to be the same strength and density as the wall blockwork.

SUBSTRUCTURE KEY

DD1 Direct Drain Connection (No.1).

SVP1 Soil Vent Pipe (No.1).

Telescopic Air Vents To Ventilate Sub Floor Void.
Air Bricks positioned at 2m max. Centres.
NOT TO BE POSITIONED BELOW DOOR THRESHOLD (Door Position
Indicated By Dashed Lines).

DOOR THRESHOLD

Thick dashed line denotes ACO 'HEX Drain Brickslot' hidden drainage
channel across width of door opening Refer to Civil Engineers design and
Architects details.

Thin dashed line indicates extent of secondary DPC stepped up to
accommodate level threshold to front door.

Foundations width and depth to be confirmed
by Engineers drawings on an individual site
by site basis.

RWP positions to be finalised on Architects
drawings on an individual site by site basis

Meter positions to be finalised on Architects
drawings on an individual site by site basis