


Notes:

- The planning, design and construction of sewers shall be in accordance with Sewerage Sector Guidance Appendix C, the Civil Engineering Specification for the Water Industry 7th Edition and AWIN Ltd amendments to CESWI.
- For rising mains, non-degradable marker tape should be laid 300 mm above the top of the pipe. For a non-metal main, the marker tape should incorporate a trace wire brought to the surface at a marker post every 1000 m (approximately) and connected to terminals on the marker post.

- Key (S104)**
- AWIN foul water sewer.
 - AWIN surface water sewer.
 - AWIN surface water inspection chamber
 - AWIN rising main.
 - AWIN headwall.
 - AWIN dry swale with underdrain.
 - AWIN SuDS feature.
 - AWIN sewer easement (3m min unless otherwise shown)
 - Highway road gully, 150mm pipe connection.
 - Highway inspection chamber
 - Highway road side dry swale with underdrain.
 - Site Boundary.



REVISIONS (CONTINUED)

Rev	Date	Description	By	Ckd	App
P02	04/06/25	Rising main alignment revised.	RAP	JD	RAP
P01	27/06/24	First Issue.	WG	RAP	RAP

REVISIONS

Rev	Date	Description	By	Ckd	App
P02	04/06/25	Rising main alignment revised.	RAP	JD	RAP
P01	27/06/24	First Issue.	WG	RAP	RAP

Hydrock
 OVER COURT BARN
 OVER LANE
 ALMONDSBURY
 BRISTOL
 BS32 4DF
 t: +44 (0) 1454 619533
 e: bristol@hydrock.com

CLIENT
CALA HOMES COTSWOLDS LTD

PROJECT
**HIMLEY VILLAGE,
 BICESTER**

TITLE
**PHASE 1B
 SECTION 104 AGREEMENT PLAN
 SHEET 5**

HYDROCK PROJECT NO.
C-27141-C

SCALE @ A1
1 : 500

STATUS DESCRIPTION
FOR APPROVAL

STATUS
S4

DRAWING NO. (PROJECT CODE-ORIGINATOR-ZONE-LEVEL-TYPE-ROLE-NUMBER)
27141-HYD-1B-XX-DR-C-0104

REVISION
P02