

BRICK/BLOCKWORK LEGEND (HOUSES)

- EXTERNAL WALLS**
- 102.5mm FACING BRICKWORK.
 - 100mm BLOCKWORK - 3.6N/mm² AIRCRETE (600-800kg/m³, 0.15W/mk).
- INTERNAL WALLS**
- 100mm BLOCKWORK - 3.6N/mm² AIRCRETE (600-800kg/m³)

- INTERNAL WALLS**
- 100mm BLOCKWORK - 3.6N/mm² AIRCRETE (600-800kg/m³)

- INTEGRAL GARAGE**
- 100mm BLOCKWORK - 3.6N/mm² AIRCRETE (600-800kg/m³) DENSITY (0.15W/MK CONDUCTIVITY) 60MM THICK URETHANE BATTS (0.022W/MK) BETWEEN 38MM X 63MM TIMBER STUDWORK ON THE GARAGE SIDE FACED WITH 12.5MM GYPSUM BASED PLASTERBOARD ON DABS WITH JOINTS TAPED AND SEALED.

- STUDWORK LEGEND**
- STUD PARTITION - 88MM OVERALL THICKNESS COMPRISING 63x38MM TIMBER STUD WITH 12.5MM PLASTERBOARD AS GYPROCK WALLBOARD EITHER SIDE.
 - BUTTRESS STUD PARTITION - 125MM OVERALL THICKNESS X 1200MM OVERALL LENGTH COMPRISING 75x50MM TIMBER STUD WITH 12MM PLYWOOD EITHER SIDE & FINISHED WITH 12.5MM PLASTERBOARD.
 - STUD PARTITION - 125MM OVERALL THICKNESS COMPRISING 100x50MM TIMBER STUD FINISHED WITH 12.5MM PLASTERBOARD. TO BE USED WHEN CONTINUING ON WITH BUTTRESS WALLS.

- REINFORCED STUD WALLS, TO SUPPORT GRAB RAILS, SEATS AND OTHER ADAPTATIONS THAT COULD IMPOSE A LOAD OF UP TO 1.5N/m². INSTALL 18mm THICK PLYWOOD BOARDS, BETWEEN STUDS.

NOTE: FOR ALL OF THE ABOVE BUILD-UP, AT WC / SHOWER / BATHROOM SIDE USE MOISTURE RESISTANT MR PLASTERBOARDS

GENERAL ARRANGEMENT DETAILS


Separating walls (E-WM-30)	EM-IW21-08-01
Timber stud partitions	EM-IW21-08-40, 41, 42, 43, 44, 70, 71, 72, 75, 79, 80
Pocket & internal doors	EM-DW21-13-50, 51, 55, 57
Cavity closer & firestopping	EM-FP21-10-01, 02, 03
Staircase fixing	EM-AD21-18-10, 11, 12
External doors & windows	EM-DW21-13-01, 04, 20, 24, 25

GUTTER SIZE & RWP POSITIONS TO BE DESIGNED BY SITE ENGINEER WITH DOWNPIPES LOCATIONS IN ACCORDANCE WITH DEVELOPMENT DRAINAGE LAYOUT, SITE CONDITIONS AND EXPANSION JOINT LOCATIONS.

REFER TO 1:20 KITCHEN LAYOUT, DWG NO. EMG51-91, FOR SETTING OUT INFORMATION

REFER TO 1:20 WC LAYOUT, DWG NO. EMG51-92, FOR SETTING OUT INFORMATION

REFER TO 1:20 UTILITY LAYOUT, DWG NO. EMG51-93, FOR SETTING OUT INFORMATION



WHEN A MASONRY PIER IS A NON BRICK DIMENSION, IF THE LENGTH CAN ACCOMMODATE +/- 1.5mm THEN ADJUST A STANDARD 10mm MORTAR JOINT TO SUIT. IF OUTSIDE OF THESE PARAMETERS, THEN A CUT BRICK IS TO BE USED.

BED JOINT REINFORCEMENT TO SE DESIGN, GENERALLY TWO COURSES BELOW AND ABOVE WINDOW OPENING EXTENDING 600MM EITHER SIDE.

MOVEMENT JOINT TO SE DESIGN

ALL STRUCTURAL STEEL ELEMENTS TO SE DESIGN AND SPECIFICATION, TO ACHIEVE MIN.1HR FIRE RESISTANCE VIA INTUMESCENT PAINT

- NOTES:**
- THIS DRAWING MUST NOT BE SCALED.
 - THIS DRAWING IS TO BE READ IN CONJUNCTION WITH ALL OTHER PROJECT DRAWINGS BY CLIENT, OTHER CONSULTANTS AND SPECIALISTS.
 - ALL DETAILS AND DRAWINGS MUST BE READ IN CONJUNCTION WITH THE TWP NATIONAL CONSTRUCTION SPECIFICATION.
 - DIMENSIONS AND CONDITIONS TO BE VERIFIED ON SITE BY THE RELEVANT CONTRACTOR PRIOR TO PROCEEDING.
 - ALL DIMENSIONS ARE IN MILLIMETRES AND LEVELS IN METERS, U.N.O.
 - DIMENSIONS ARE TO STRUCTURAL FACES OR CENTRES, NOT FINISHES, U.N.O.
 - STANDARD INDUSTRY SOLUTIONS AND MANUFACTURER'S GUIDELINES APPLY, U.N.O.
 - THE COPYRIGHT OF THE DRAWINGS AND DESIGNS CONTAINED THEREIN REMAINS WITH TAYLOR WIMPEY AND MARK REEVES ARCHITECTS.

Taylor Wimpey Health, Safety & Environmental Information

Extracted from the Significant Risk Register of the Taylor Wimpey EMG51 Product Risk Assessment Document

All works must be carried out by a competent contractor working to an agreed safe system of work which reflects the controls highlighted below.

3. Safe system of work identified in the TWUK Site HSE Manual. Control risk of fall and manual handling operation when transferring plasterboard from one storey to another by using a plasterboard slot formed in the floor or other similar approved control measures.

6. Safe system of work identified in the TWUK Site HSE Manual. Where external core drilling for flues/ducting/extraction units is required. Scaffolding access tower must be used and dust control measures included.

8. Due to the risk of customers falling during routine light bulb replacement, consideration must be taken to the positioning/placement of light fittings and stairwells. The entire point of the assessment of risk is to eliminate the risk by design.

- NOTES:**
- LOCATION OF HOT WATER CYLINDER UNDER STAIR TBC
 - CONFIRM DOOR CLEARANCE FOR CYLINDER MAINTENANCE
 - RADIATOR SIZE IN ABEYANCE, SUBJECT TO SPECIALIST DESIGNER'S CALCULATION

REV	DATE	DESCRIPTION OF REVISION	DRAWN	CHECKED
C03	11.03.26	Step base banding highlighted in green	SN	LE
C02	05.12.25	Compliance amended to M4(1)	MS	SN
C01	13.10.25	STATUS TO CONSTRUCTION	JF	LE
T03	24.09.25	Double door D12 replaced with single leaf. Block pier omitted between D11 & D12 and door positions shifted; Stepped base outline added as planning	SN	LE
T02	20.06.25	Studwork legend updated	CC	LE
T01	22.04.25	STATUS TO TENDER; W1 updated	CC	LE
P03	31.03.25	Steel beam added as to SE mark-up	CK	LE
P02	19.03.25	HPP added; WWHR removed	CC	LE

Status: **CONSTRUCTION**
 NDSS Compliance: **COMPLIANT** ADM Compliance Level: **M4(1)**

Mark Reeves Architects
 5 Northfields Prospect, Putney Bridge Road, London, SW18 1PE
 T e l : 020 8874 0484 Email: mail@mrarchitects.co.uk

Project No: **23/1024**
 Drg No: **EMG51 - 21P2 - 21 - C03**

Project: **Grange Farm, WD (Phase 2)**
 Drgw Title: **PATTERHAM 5B9P GA GROUND FLOOR**

AS PLOT/S: 124
 OPP PLOT/S: 65

Scale: 1:50 @ A3 Date: Jan 2025
 Drawn By: CC Checked By: RB

Client: **Taylor Wimpey UK Ltd**
 Gate House, Turnpike Road, High Wycombe, Bucks HP12 3NR
 Tel 01494 558323 Fax 01494 885663 www.taylorwimpey.com

GROUND FLOOR PLAN - AS
 EMG51 (5B9P)

REFER TO SITE LAYOUT AND BLOCK PLANS FOR PARTY WALL AND ROOF CONDITIONS SEMI/DETACHED PLOTS.

SEE SITE LAYOUT FOR CHARACTER AREAS, MATERIALS AND ORNAMENT; REFER TO ELEVATION AND SCHEDULE FOR WINDOW PANE CONFIGURATION.